



Glenn Grieb
Plant Manager
VEOLIA WATER NORTH AMERICA

KinBuc Landfill Treatment Plant
383 Meadow Road
Edison, NJ 08817
www.veoliawatema.com

May 21st, 2004

Ms. Grissel V. Diaz-Cotto
Emergency and Remedial Response Division
United States Environmental Protection Agency
Region II
290 Broadway, 19th Floor
New York, NY 10007-1866

Re: April 2004 Discharge Monitoring Report
Leachate Treatment Plant, Operable Unit 1
Kin-Buc Landfill Superfund Site

Dear Ms. Diaz-Cotto:

The April 2004 Discharge Monitoring Report (DMR) for the Leachate Treatment Plant of Operable Unit 1, Kin-Buc Landfill Superfund Site, prepared by Veolia Water Operating Services is attached. We will provide copies of the DMR to Ms. Martha Goodwin at the NJDEP.

Should you have any questions concerning the DMR or other site items, please contact me at your earliest convenience at the Kin-Buc site.

Very truly yours,
Veolia Water Operating Services
On behalf of SCA Services, Inc.,

Glenn Grieb
Plant Manager

Enclosure

cc: Martha Goodwin – NJDEP
Stephen Joyce – SCA Holding
Carl Januszkiewicz – Waste Management
Richard Hoyt – Veolia Water OS



562171



NEW JERSEY DEPARTMENT OF ENVIRONMENTAL PROTECTION
DIVISION OF WATER QUALITY

MONITORING REPORT - TRANSMITTAL SHEET

NJPDES NO.
* ☐ ☐ ☐ ☐ ☐ ☐ ☐ ☐
*NJ Permit Equivalent

REPORTING PERIOD
M o. Y r. M o. Y r.

PERMITTEE: Name: SCA Services, Inc.
Address: 383 Meadow Road
Edison, New Jersey 08817

FACILITY: Name: Kin-Buc Landfill
Address: 383 Meadow Road
Edison, New Jersey 08817
Telephone: 732-572-4743

FORMS ATTACHED (Indicate Quantity of Each)

Operating Exceptions

SLUDGE REPORT-SANITARY
__ T-VWX-007 __ T-VWX-008 __ T-VWX-009
__ EPA Form 3320-1

DYE TESTING YES NO
__ X

SLUDGE REPORT-INDUSTRIAL
__ T-VWX-010A __ T-VWX-010B

TEMPORARY BYPASSING __ X

DISINFECTION INTERRUPTION __ X

WASTEWATER REPORTS
__ T-VWX-011 __ T-VWX-012 __ T-VWX-013

MONITORING MALFUNCTIONS __ X

GROUNDWATER REPORTS
__ T-VWX-015(A,B) __ T-VWX-016 __ T-VWX-017
__ ELECTRONIC SUBMISSION

UNITS OF OPERATION __ X

OTHER __ X

NPDES DISCHARGE MONITORING
__ EPA Form 3320-1


(Detail any "Yes" on reverse side in appropriate space.)


NOTE: The "Hours Attended at Plant" on the reverse of this sheet must also be completed.

AUTHENTICATION I certify under penalty of law that this document and all attachments were prepared under the direction or supervision in accordance with a system designed to assure my inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

LICENSED OPERATOR

PRINCIPAL EXECUTIVE OFFICER OR
DULY AUTHORIZED REPRESENTATIVE

Name (Printed) Glenn Grieb
Grade & Registry No. N-4 ; 0021212
Signature 

Name (Printed) Glenn Grieb
Title (Printed) Plant Operations Manager
Signature 

Date May 21st, 2004

[illegible]

Day of Month
Licensed Operator
Others

Day of Month
Licensed Operator
Others

1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
8	8	0	6	8	10	3	8	8	0	0	8	8	0	0	0
8	8	6	0	16	16	16	16	16	6	6	16	16	16	16	16
17	18	19	20	21	22	23	24	25	26	27	28	29	30		
0	0	0	0	8	8	8	0	0	8	8	8	8	8		
12	6	16	16	16	16	8	6	4	16	16	16	16	16		

PERMITTEE NAME/ADDRESS

NAME SCA SERVICES, INC.
ADDRESS 383 MEADOW ROAD
EDISON, NEW JERSEY 08817

FACILITY
LOCATION

KIN-BUC LANDFILL
EDISON, NEW JERSEY
CARL JANUSZKIEWICZ

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM
DISCHARGE MONITORING REPORT

NJ PERMIT EQUIVALENT
PERMIT NUMBER

001
DISCHARGE NUMBER

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
04	04	01	04	04	30

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
FLOW	SAMPLE MEASUREMENT	0.031065	0.034311	MGD	*****	*****	*****	***	***	continuous	flow meter
	PERMIT REQUIREMENT	REPORT	ONLY		*****	*****	*****			continuous	flow meter
pH	SAMPLE MEASUREMENT	*****	*****	***	7.85	*****	8.11	S.U.	0	1/week	grab
	PERMIT REQUIREMENT	*****	*****		6.0	*****	9.0			weekly	grab
PETROLEUM HYDROCARBONS	SAMPLE MEASUREMENT	*****	*****	***	*****	<1.000	<1.000	mg/l	0	2/month	grab
	PERMIT REQUIREMENT	*****	*****		*****	10	15			2/month	grab
COD	SAMPLE MEASUREMENT	8.52	17.02	kg/day	*****	136	152	mg/l	0	2/month	comp.
	PERMIT REQUIREMENT	REPORT	ONLY		*****	REPORT	ONLY			2/month	comp.
BOD	SAMPLE MEASUREMENT	*****	*****	***	*****	<5.00	<5.00	mg/l	0	2/month	comp.
	PERMIT REQUIREMENT	*****	*****		*****	56	220			2/month	comp.
TOTAL SUSPENDED SOLIDS	SAMPLE MEASUREMENT	7.93	2.38	kg/day	*****	17.25	23.00	mg/l	0	1/week	comp.
	PERMIT REQUIREMENT	REPORT	ONLY		*****	30	45(1)			weekly	comp.
DISSOLVED OXYGEN	SAMPLE MEASUREMENT	*****	*****	***	8.03	*****	*****	mg/l	0	1/week	grab
	PERMIT REQUIREMENT	*****	*****		4.0 MIN instantaneous	*****	*****			weekly	grab
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER		I certify under penalty of law that I have personally examined and I am familiar with the information submitted herein, and based on my inquiry of those individuals immediately responsible for obtaining the information, I believe the submitted information is true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment. See 18 U.S.C. 1001 & 33 U.S.C. 1319. (Penalties under these statutes may include fines up to \$10,000 and or maximum imprisonment of between 6 months and 5 years)					TELEPHONE		DATE		
Glenn Grieb Project Manager							732 572-4743		04 05 21		
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT					AREA CODE	NUMBER	YEAR MO DAY		

COMMENTS AND EXPLANATIONS OF ANY VIOLATIONS

(REFERENCE ALL ATTACHMENTS HERE)

PERMITTEE NAME/ADDRESS

NAME
ADDRESS

FACILITY
LOCATION
ATTN:

SCA SERVICES, INC.
383 MEADOW ROAD
EDISON, NEW JERSEY 08817

KIN-BUC LANDFILL
EDISON, NEW JERSEY
CARL JANUSZKIEWICZ

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM
DISCHARGE MONITORING REPORT

NJ PERMIT EQUIVALENT			001		
PERMIT NUMBER			DISCHARGE NUMBER		
MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
04	04	01	04	04	30

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
BENZENE	SAMPLE MEASUREMENT	0.0000354	0.0000371	kg/day	*****	<0.30	<0.30	ug/L	0	2/month	grab
	PERMIT REQUIREMENT	0.000	0.02		*****	57	134			2/month	grab
CHLOROBENZENE	SAMPLE MEASUREMENT	<0.0000236	<0.0000247	kg/day	*****	<0.20	<0.20	ug/L	0	2/month	grab
	PERMIT REQUIREMENT	0.022	0.058		*****	142	380			2/month	grab
1,1 DICHLOROETHENE	SAMPLE MEASUREMENT	<0.0000236	<0.0000247	kg/day	*****	<0.20	<0.20	ug/L	0	2/month	grab
	PERMIT REQUIREMENT	0.003	0.008		*****	22	59			2/month	grab
ETHYLBENZENE	SAMPLE MEASUREMENT	<0.0000472	<0.0000495	kg/day	*****	<0.40	<0.40	ug/L	0	2/month	grab
	PERMIT REQUIREMENT	0.022	0.058		*****	142	380			2/month	grab
TETRACHLOROETHYLENE	SAMPLE MEASUREMENT	<0.0000354	<0.0000371	kg/day	*****	<0.30	<0.30	ug/L	0	2/month	grab
	PERMIT REQUIREMENT	0.008	0.025		*****	52	184			2/month	grab
TOLUENE	SAMPLE MEASUREMENT	<0.0000236	<0.0000247	kg/day	*****	<0.20	<0.20	ug/L	0	2/month	grab
	PERMIT REQUIREMENT	0.004	0.011		*****	28	74			2/month	grab
1,2-TRANSDICHLOROETHYLENE	SAMPLE MEASUREMENT	<0.0000236	<0.0000247	kg/day	*****	<0.20	<0.20	ug/L	0	2/month	grab
	PERMIT REQUIREMENT	0.004	0.008		*****	25	80			2/month	grab
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER		I certify under penalty of law that I have personally examined and I am familiar with the information submitted herein, and based on my inquiry of those individuals immediately responsible for obtaining the information, I believe the submitted information is true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment. See 18 U.S.C. 1001 & 33 U.S.C. 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years)					TELEPHONE		DATE		
Glenn Grieb Project Manager							732 572-4743		04 05 21		
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT					732 572-4743		04 05 21		


COMMENTS AND EXPLANATIONS OF ANY VIOLATIONS (REFERENCE ALL ATTACHMENTS HERE)

PERMITTEE NAME/ADDRESS
NAME SCA SERVICES, INC.
ADDRESS 383 MEADOW ROAD
EDISON, NEW JERSEY 08817

FACILITY KIN-BUC LANDFILL
LOCATION EDISON, NEW JERSEY
ATTN: CARL JANUSZKIEWICZ

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM
DISCHARGE MONITORING REPORT

NJ PERMIT EQUIVALENT			001			
PERMIT NUMBER			DISCHARGE NUMBER			
MONITORING PERIOD						
YEAR	MO	DAY	TO	YEAR	MO	DAY
04	04	01		04	04	30

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE			
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			YEAR	MO	DAY	
TRICHLOROETHYLENE	SAMPLE MEASUREMENT	<0.0000236	<0.0000247	kg/day	*****	<0.20	<0.20	ug/L	0	2/month	grab			
	PERMIT REQUIREMENT	0.004	0.018		*****	26	69			2/month	grab			
VINYL CHLORIDE	SAMPLE MEASUREMENT	<0.0000562	<0.0000619	kg/day	*****	<0.50	<0.50	ug/L	0	1/week	grab			
	PERMIT REQUIREMENT	0.008	0.018		*****	52.8	106			weekly	grab			
ACENAPHTHYLENE	SAMPLE MEASUREMENT	<0.0000084	<0.0000088	kg/day	*****	<0.071	<0.071	ug/L	0	1/month	grab			
	PERMIT REQUIREMENT	0.00026	0.00052		*****	1.72	3.43			monthly	grab			
BENZO(A)ANTHRACENE	SAMPLE MEASUREMENT	<0.0000236	<0.0000247	kg/day	*****	<0.20	<0.20	ug/L	0	1/month	grab			
	PERMIT REQUIREMENT	0.00026	0.00052		*****	1.72	3.43			monthly	grab			
BENZO(A)PYRENE	SAMPLE MEASUREMENT	<0.0000097	<0.0000101	kg/day	*****	<0.082	<0.082	ug/L	0	1/month	grab			
	PERMIT REQUIREMENT	0.00026	0.00052		*****	1.72	3.43			monthly	grab			
BENZO(ghi)PERYLENE	SAMPLE MEASUREMENT	<0.0000072	<0.0000075	kg/day	*****	<0.061	<0.061	ug/L	0	1/month	grab			
	PERMIT REQUIREMENT	0.00026	0.00052		*****	1.72	3.43			monthly	grab			
BENZO(k)FLUORANTHENE	SAMPLE MEASUREMENT	<0.0000236	<0.0000247	kg/day	*****	<0.20	<0.20	ug/L	0	1/month	grab			
	PERMIT REQUIREMENT	0.00026	0.00052		*****	1.72	3.43			monthly	grab			
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER		I certify under penalty of law that I have personally examined and I am familiar with the information submitted herein, and based on my inquiry of those individuals immediately responsible for obtaining the information, I believe the submitted information is true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment. See 18 U.S.C. 1001 & 33 U.S.C. 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years)								TELEPHONE		DATE		
Glenn Grieb Project Manager										732 572-4743		04 05 21		
										AREA CODE	NUMBER	YEAR	MO	DAY
TYPED OR PRINTED						SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT								

PERMITTEE NAME/ADDRESS

NAME

ADDRESS

FACILITY

LOCATION

ATTN:

SCA SERVICES, INC.
383 MEADOW ROAD
EDISON, NEW JERSEY 08817

KIN-BUC LANDFILL
EDISON, NEW JERSEY
CARL JANUSZKIEWICZ

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM
DISCHARGE MONITORING REPORT

NJ PERMIT EQUIVALENT
PERMIT NUMBER

001
DISCHARGE NUMBER

MONITORING PERIOD

YEAR	MO	DAY	TO	YEAR	MO	DAY
04	04	01		04	04	30

PARAMETER		QUANTITY OR LOAD			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE			
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			YEAR	MO	DAY	
IDENO(1,2,3cd) PYRENE	SAMPLE MEASUREMENT	<0.0000097	<0.0000101	kg/day	*****	<0.082	<0.082	ug/L	0	1/month	grab			
	PERMIT REQUIREMENT	0.00026	0.00052		*****	1.72	3.43			monthly	grab			
PHENANTHRENE	SAMPLE MEASUREMENT	<0.0000112	<0.0000124	kg/day	*****	<0.10	<0.10	ug/L	0	1/week	grab			
	PERMIT REQUIREMENT	REPORT	ONLY		*****	REPORT ONLY	5.4(2)			weekly	grab			
ALDRIN	SAMPLE MEASUREMENT	<0.0000012	<0.0000012	kg/day	*****	<0.01	<0.01	ug/L	0	1/month	grab			
	PERMIT REQUIREMENT	0.000133	0.00026		*****	0.0875	0.175			monthly	grab			
4,4-DDT	SAMPLE MEASUREMENT	<0.0000011	<0.0000012	kg/day	*****	<0.01	<0.01	ug/L	0	1/week	grab			
	PERMIT REQUIREMENT	0.0000578	0.000148		*****	0.38	0.765			weekly	grab			
PCB-1242	SAMPLE MEASUREMENT	<0.0000225	<0.0000247	kg/day	*****	<0.20	<0.20	ug/L	0	1/week	grab			
	PERMIT REQUIREMENT	REPORT	ONLY		*****	REPORT ONLY	0.5(2)			weekly	grab			
PCB-1248	SAMPLE MEASUREMENT	<0.0000309	<0.0000371	kg/day	*****	<0.28	<0.30	ug/L	0	1/week	grab			
	PERMIT REQUIREMENT	REPORT	ONLY		*****	REPORT ONLY	0.5(2)			weekly	grab			
PCB-1254	SAMPLE MEASUREMENT	<0.0000225	<0.0000247	kg/day	*****	<0.20	<0.20	ug/L	0	1/week	grab			
	PERMIT REQUIREMENT	REPORT	ONLY		*****	REPORT ONLY	0.5(2)			weekly	grab			
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER		I certify under penalty of law that I have personally examined and I am familiar with the information submitted herein, and based on my inquiry of those individuals immediately responsible for obtaining the information, I believe the submitted information is true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment. See 18 U.S.C. 1001 & 33 U.S.C. 1319. (Penalties under these statutes may include fines up to \$10,000 and or maximum imprisonment of between 6 months and 5 years)							TELEPHONE		DATE			
Glenn Grieb Project Manager									732		572-4743		04	05
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT							AREA CODE	NUMBER				

(REFERENCE ALL ATTACHMENTS HERE)

PERMITTEE NAME/ADDRESS

NAME
ADDRESS

FACILITY
LOCATION
ATTN:

SCA SERVICES, INC.
383 MEADOW ROAD
EDISON, NEW JERSEY 08817

KIN-BUC LANDFILL
EDISON, NEW JERSEY
CARL JANUSZKIEWICZ

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM
DISCHARGE MONITORING REPORT

NJ PERMIT EQUIVALENT
PERMIT NUMBER

001
DISCHARGE NUMBER

MONITORING PERIOD					
YEAR	MO	DAY	TO		
04	04	01			
YEAR	MO	DAY			
04	04	30			

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE		
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			YEAR	MO	DAY
PCB-1260	SAMPLE MEASUREMENT	<0.000309	<0.000371	kg/day	*****	<0.28	<0.30	ug/L	0	1/week	grab		
	PERMIT REQUIREMENT	REPORT	ONLY		*****	REPORT ONLY	0.5(2)			weekly	grab		
ARSENIC	SAMPLE MEASUREMENT	0.0004955	0.0005940	kg/day	*****	4.40	5.30	ug/L	0	1/week	comp		
	PERMIT REQUIREMENT	0.013	0.028		*****	85.8	172			weekly	comp		
CADMIUM	SAMPLE MEASUREMENT	<0.0000449	<0.0000495	kg/day	*****	<0.40	<0.40	ug/L	0	1/week	comp		
	PERMIT REQUIREMENT	0.0073	0.017		*****	48.2	112			weekly	comp		
CHROMIUM	SAMPLE MEASUREMENT	0.0004500	0.0005940	kg/day	*****	4.00	4.90	ug/L	0	1/week	comp		
	PERMIT REQUIREMENT	0.030	0.080		*****	198	396			weekly	comp		
COPPER	SAMPLE MEASUREMENT	0.0003522	0.0004067	kg/day	*****	3.2	3.7	ug/L	0	1/week	comp		
	PERMIT REQUIREMENT	REPORT	ONLY		*****	REPORT ONLY	10			weekly	comp		
LEAD	SAMPLE MEASUREMENT	<0.0001460	<0.0001609	kg/day	*****	<1.30	<1.30	ug/L	0	1/week	comp		
	PERMIT REQUIREMENT	REPORT	ONLY		*****	REPORT ONLY	10			weekly	comp		
NICKEL	SAMPLE MEASUREMENT	0.0024470	0.0026977	kg/day	*****	21.8	22.5	ug/L	0	1/week	comp		
	PERMIT REQUIREMENT	0.140	0.281		*****	824	1860			weekly	comp		
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER		I certify under penalty of law that I have personally examined and I am familiar with the information submitted herein, and based on my inquiry of those individuals immediately responsible for obtaining the information, I believe the submitted information is true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment. See 18 U.S.C. 1001 & 33 U.S.C. 1319. (Penalties under these statutes may include fines up to \$10,000 and or maximum imprisonment of between 6 months and 5 years)					TELEPHONE		DATE				
Glenn Grieb Project Manager							732 572-4743		04 05 21				
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT					AREA CODE	NUMBER	YEAR	MO	DAY		

COMMENTS AND EXPLANATIONS OF ANY VIOLATIONS

(REFERENCE ALL ATTACHMENTS HERE)

PERMITTEE NAME/ADDRESS

NAME

ADDRESS

FACILITY

LOCATION

ATTN:

SCA SERVICES, INC.
383 MEADOW ROAD
EDISON, NEW JERSEY 08817

KIN-BUC LANDFILL
EDISON, NEW JERSEY
CARL JANUSZKIEWICZ

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM
DISCHARGE MONITORING REPORT

NJ PERMIT EQUIVALENT
PERMIT NUMBER

001
DISCHARGE NUMBER

MONITORING PERIOD
YEAR MO DAY TO YEAR MO DAY
04 04 01 TO **04 04 30**

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
ZINC	SAMPLE MEASUREMENT	0.0025359	0.0033762	kg/day	*****	22.9	32.6	ug/L	0	1/week	comp
	PERMIT REQUIREMENT	0.127	0.353		*****	1170	2350			weekly	comp
CYANIDE	SAMPLE MEASUREMENT	<0.0011231	<0.0012375	kg/day	*****	<10.0	<10.0	ug/L	0	1/week	comp
	PERMIT REQUIREMENT	0.802	0.004		*****	12.2	26.4			weekly	comp
ALUMINUM	SAMPLE MEASUREMENT	0.0092517	0.0149733	kg/day	*****	80.9	121.0	ug/L	0	1/week	comp
	PERMIT REQUIREMENT	1.40	2.31		*****	9248	18500			weekly	comp
IRON	SAMPLE MEASUREMENT	0.0057120	0.0078579	kg/day	*****	50.7	63.5	ug/L	0	1/week	comp
	PERMIT REQUIREMENT	88.8	162		*****	532000	1070000			weekly	comp
ACUTE TOXICITY, (LC50)	SAMPLE MEASUREMENT	QUARTELY	REPORT	***	>100	*****	*****	%	0		
	PERMIT REQUIREMENT	*****	*****		50(3)	*****	*****			see permit	equivalent
Ammonia	SAMPLE MEASUREMENT	*****	*****	***	*****	<0.100	<0.100	mg/l	0	*****	*****
	PERMIT REQUIREMENT	*****	*****		*****	4.5	10.0			2/month	comp
	SAMPLE MEASUREMENT	*****	*****	***	*****	*****	*****	***	***	*****	*****
	PERMIT REQUIREMENT	*****	*****		*****	*****	*****			*****	*****
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER		I certify under penalty of law that I have personally examined and am familiar with the information submitted herein, and based on my inquiry of those individuals immediately responsible for obtaining the information, I believe the submitted information is true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment. See 18 U.S.C. 1001 & 33 U.S.C. 1319. (Penalties under these statutes may include fines up to \$10,000 and or maximum imprisonment of between 6 months and 5 years)					TELEPHONE		DATE		
Glenn Grieb Project Manager							732 572-4743		04 05 21		
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT					AREA CODE	NUMBER	YEAR	MO	DAY

COMMENTS AND EXPLANATIONS OF ANY VIOLATIONS

(REFERENCE ALL ATTACHMENTS HERE)